



SV Sistemi di Sicurezza Srl
Headquarters: Via Cortesi, 1
24020 Villa di Serio, Bergamo (Italy)
Tel. +39.035.65.70.55 Fax. +39.035.66.19.64
www.svsistemidisicurezza.com
email: info@svsistemidisicurezza.com

DECLARATION OF PERFORMANCE
according to Construction Product Regulation EU N° 305/2011

n° 001DOP2013

1 – *Unique Product identification code:*

EXFIRE360 – Fire detection and fire alarm panel

2 – *Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):*

EXFIRE360

3 – *Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:*

**Control and Indicating Equipment with integrated Power Supply Equipment
for use in fire detection and fire alarm systems installed in buildings**

4 – *Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):*

**SV Sistemi di Sicurezza Srl
Via Cortesi, 1
24020 – Villa di Serio, Bergamo
ITALY**

5 – *Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):*

Not Applicable

6 – *System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:*

System 1

7 – *In case of the declaration of performance concerning a construction product covered by a harmonized standard:*

IMQ ISTITUTO ITALIANO DEL MARCHIO DI QUALITÀ S.p.A. – 0051

performed type testing and the initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and approval of the factory production control under system 1

and issued following certificate of constancy of performance:

0051 – CPD – 0369

8 – *In case of the declaration of performance concerning a construction product which a European Technical Assessment has been issued:*

Not Applicable – see item 7



SV Sistemi di Sicurezza Srl
Headquarters: Via Cortesi, 1
24020 Villa di Serio, Bergamo (Italy)
Tel. +39.035.65.70.55 Fax. +39.035.66.19.64
www.svsistemidisicurezza.com
email: info@svsistemidisicurezza.com

9 – Declared performance:

all requirements including the essential characteristics and the corresponding performances for the intended use or uses indicated in point 3 above have been determined as described in the hEN listed below:

- EN 54-2:1997+A1:2006
- EN 54-4:1997+A1:2002+A2:2006
- EN 60950-1:2006

10 – *The performance of the product identified in points 1 and 2 is in conformity with the standards in point 9 and certified by authorized Notified Body 0051 with EC Certificate of Conformity N. 0051-CPD-0369.*

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Fabio Massimo Turani

Mr. Fabio M. Turani
Technical Department
Villa di Serio, Bergamo
1st July 2013