

# **BRE Certification Limited and LPCB**

*Bucknalls Lane, Garston, Watford, Hertfordshire, WD25 9XX*

*Telephone: 01923 664100 Fax: 01923 664603 E-mail: enquiries@bre-certification.co.uk Web: www.bre-certification.co.uk*

## **EC-CERTIFICATE OF CONFORMITY**

### **0832 - CPD - 0141**

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

### **Symphoni SY/C Conventional Type A fire alarm wall sounder for use in fire detection and alarm systems**

*(For conditions of use for the product see the attached appendix)*

placed on the market by

**Fulleon Limited**

**Llantarnam Park, Cwmbran, Gwent, NP44 3AW**

and produced in the factory

**Fulleon Limited**

**Llantarnam Park, Cwmbran, Gwent, NP44 3AW**


is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan. The initial type-testing for the relevant characteristics of the product, the initial inspection and continuous surveillance of the factory and factory production control has been performed under the control of the approved body BRE Certification Limited.

This certificate attests that all provisions concerning the attestation of conformity (Level 1) and the performances described in Annex ZA of the standard(s)

### **EN 54 - 3: 2000 + A1: 2002 - Fire detection and fire alarm systems - Fire alarm devices - Sounders**

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 16/9/2005 and remains valid as long as the product continues to be manufactured and the conditions laid down in the harmonised technical specification referenced or the manufacturing conditions in the factory or the FPC itself are not modified significantly and the required annual FPC assessments are maintained.



Nigel Smithies  
For and on behalf of BRE Certification Limited

Date of Issue: 16/9/2005  
Issue Number: 1  
Page: 1 of 2

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.  
To check the authenticity of this certificate, please visit our website or contact us.

## **BRE Certification Limited and LPCB**

*Bucknalls Lane, Garston, Watford, Hertfordshire, WD25 9XX*

*Telephone: 01923 664100 Fax: 01923 664603 E-mail: [enquiries@bre-certification.co.uk](mailto:enquiries@bre-certification.co.uk) Web: [www.bre-certification.co.uk](http://www.bre-certification.co.uk)*

### **Appendix to EC Certificate of conformity 0832 - CPD - 0141**

The details and conditions of use for the Symphoni SY/C Conventional Type A fire alarm wall sounder, placed on the market by Fulleon Limited are:

To be used in accordance with the suppliers installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

**Bases:**

Standard mounting back box

**Sounder Tones:**

SY/C, SY/C/WP:

29 - Alternating 990Hz 250ms - 650Hz 250ms

33 - Continuous 990Hz steady

34 - Intermittent 990Hz 500ms - silence 500ms

SY/C/E, SY/C/E/WP:

7 - Slow whoop 500Hz - 1200Hz in 3.5s - 0.5s silence

8 - Sweep 1200Hz - 500Hz in 1s

33 - Continuous 990Hz steady

**Variants:**

/WP - Weatherproof variant (Type B)

/E - European tone variant

/C - All colour variants

Nigel Smithies

For and on behalf of BRE Certification Limited

Date of Issue: 16/9/2005

Issue Number: 1

Page: 2 of 2

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.

To check the authenticity of this certificate, please visit our website or contact us.